

Raptor Interactions with Electrical Systems: Progress and Knowledge Gaps

Author: Dwyer, James F.

Source: Journal of Raptor Research, 54(2) : 89-92

Published By: Raptor Research Foundation

URL: <https://doi.org/10.3356/0892-1016-54.2.89>

BioOne Complete (complete.BioOne.org) is a full-text database of 200 subscribed and open-access titles in the biological, ecological, and environmental sciences published by nonprofit societies, associations, museums, institutions, and presses.

Your use of this PDF, the BioOne Complete website, and all posted and associated content indicates your acceptance of BioOne's Terms of Use, available at www.bioone.org/terms-of-use.

Usage of BioOne Complete content is strictly limited to personal, educational, and non - commercial use. Commercial inquiries or rights and permissions requests should be directed to the individual publisher as copyright holder.

BioOne sees sustainable scholarly publishing as an inherently collaborative enterprise connecting authors, nonprofit publishers, academic institutions, research libraries, and research funders in the common goal of maximizing access to critical research.

THE JOURNAL OF RAPTOR RESEARCH

A QUARTERLY PUBLICATION OF THE RAPTOR RESEARCH FOUNDATION, INC.

VOL. 54

JUNE 2020

No. 2

J. Raptor Res. 54(2):89–92

© 2020 The Raptor Research Foundation, Inc.

RAPTOR INTERACTIONS WITH ELECTRICAL SYSTEMS: PROGRESS AND KNOWLEDGE GAPS

JAMES F. DWYER¹

EDM International, Fort Collins, CO 80525 USA

KEY WORDS: *Conservation; electric utility; electrocution; mitigation; power line; power pole; retrofitting; transmission line.*

In 2018, in Kruger National Park, South Africa, the Raptor Research Foundation (RRF) hosted a symposium on raptor interactions with electric systems. Attendees presented summaries of decades of electrocution and collision research in South Africa, evidence of huge numbers of electrocutions in Europe and Asia, evidence that raptors hatched in Europe were being electrocuted in North Africa, and results of studies of a variety of new electrocution and collision mitigation measures being developed and tested in North America and elsewhere.

In the following pages, the *Journal of Raptor Research* (JRR) has assembled many of those presented papers, and a few others, into a special issue focused on raptor interactions with electric systems. This issue includes valuable new incidence data, descriptions of refinements to existing information or techniques, and perhaps most importantly, a highlighting of crucial knowledge gaps. Novel data include descriptions by Dixon et al. (2020) and Sarasola et al. (2020) of electrocutions of Saker Falcons (*Falco cherrug*) in Mongolia and Chaco Eagles (*Buteogallus coronatus*) in Argentina. Heck and Schwartz (2020) and Kemper et al. (2020) describe raptor interactions with electric systems in Canada. Collectively, these four papers provide important new data on raptors' interactions with electrical systems outside the most studied areas of North America and Europe. Tincher et al. (2020) describe assessment of perch deterrents in a model system, and Dwyer et al. (2020c) describe mechanical failures of perch deterrents on a real-world power line. Comparing the lessons learned in these two studies, and in the

foundational studies they cite, may help readers think more deeply about the likely effectiveness of perch deterrents in the electric systems they study or manage. The effectiveness of recently developed perch deterrent strategies is a particularly important knowledge gap (Dixon et al. 2019, Slater et al. 2020).

Within this volume, Smith et al. (2020) and Mojica et al. (2020) provide the only mentions in this special issue of raptors' interactions with renewable energy infrastructure and collision risk, respectively. Additional research into raptors' interactions with renewable energy infrastructure and the transmission lines connecting renewable energy to the electric grid is particularly needed. To date, raptor management at renewable energy sources has focused mostly on direct effects of collision mortality, but management also needs to consider indirect effects of habitat loss or abandonment (Smith and Dwyer 2016) related not only to project footprints, but also to the new transmission lines connecting renewable energy facilities to existing power grids. Collisions also remain impactful for some species and in some areas (Mojica et al. 2009, Shaw et al. 2018).

Some of the articles herein offer steps forward, which though perhaps not entirely novel, do nonetheless add to our knowledge base. Dwyer et al. (2020a) for example provides a map of distribution power pole density throughout much of the western USA. Although previous maps of pole density were already available for Colorado and Wyoming (Dwyer et al. 2016), and for other portions of the western USA (Dwyer et al. 2017), this new work expands the range of pole density mapping in

¹ Email address: jdwyer@edmlink.com

North America, makes that mapping more accessible, and serves as a foundational component of Bedrosian et al. (2020). Understanding pole density is also useful in understanding implications of Dwyer et al.'s (2020b) study of Golden Eagles that perch on power poles.

Bringing many of these pieces together into a concise summary, Slater et al. (2020) have contributed a Conservation Letter to this special issue. The intent of the Conservation Letter is to provide a scientific review of raptor interactions with power lines and serve as a go-to publication for the perspective of the Raptor Research Foundation. The hope is that the combination of novel study areas described (Dixon et al. 2020, Heck and Schwartz 2020, Kemper et al. 2020, Sarasola et al. 2020), novel data (Bedrosian et al. 2020, Dwyer et al. 2020a, 2020b, 2020c, Mojica et al. 2020, Smith et al. 2020, Tincher et al. 2020), and a Raptor Research Foundation Conservation Letter (Slater et al. 2020) will enable readers of this special issue to identify areas where additional work is needed to mitigate negative interactions between raptors and electric systems. The special issue is missing recent European perspectives. For those, see Demeter et al. (2018), Guil et al. (2018), Hernández-Lambrano et al. (2018), and Moreira et al. (2018).

Unfortunately, many gaps in knowledge of raptors' interactions with electrical systems remain. For example, researchers have rarely invested the time and effort required to quantitatively assess the role of proximity of nests to power poles as an electrocution risk factor. That is because, at least in the USA, electrocution mitigation is largely organized and prioritized by consulting companies, which must move quickly through service areas to evaluate as many poles as possible in the shortest amount of time. Raptor nest locations are generally considered only in the context of circular buffers determined by regulators, or when nests are placed directly on utility infrastructure. Even when consulting companies request nest location data, the necessary data may not be available to, or may not be provided by wildlife managers. Researchers should do a better job of incorporating raptor nest locations in understanding electrocution risk and wildlife managers should be more willing, authorized, or supported financially to share nest location data with consulting companies working to develop Risk Assessments for Avian Protection Plans.

So, where does raptor conservation go from here? In the face of ever-increasing global reports of electrocutions and collisions with electrical systems, of power line networks and renewable energy expanding rapidly, and of the recent revelation that 25% of birds in North America have disappeared since 1970 (Rosenberg et al. 2019), the raptors we study need us to transition from research to applied conservation.

One example of how the research described in this special issue can be applied to conservation is illustrated by Bedrosian et al. (2020). Bedrosian et al. (2020) combined maps of power pole density with maps of Golden Eagle (*Aquila chrysaetos*) habitat and data on Golden Eagle electrocutions to create a predictive model of Golden Eagle electrocutions risk in northeastern Wyoming. The model is being used by a local electric utility to help determine which power poles should be prioritized for retrofitting (modifying to reduce electrocution risk). Scaling up, this approach has the potential to be used in decision-making for distributing financial resources from in-lieu fee programs being developed by the US Fish and Wildlife Service. In these programs, fees paid by wind energy developers for anticipated Golden Eagle collision mortalities at wind turbines are used to fund electrocution mitigation of power lines. The intent is to prevent 1.2 Golden Eagle electrocutions for every one Golden Eagle collision mortality. Could this become a model for global mitigation of raptor electrocutions?

Some of the research described in this special issue might also contribute to conservation by serving as a foundation for more informed Avian Protection Plans (APPs). APPs are documents electric utilities use to guide modifications of their electric systems and operations to reduce the risks of avian electrocutions (mostly on distribution lines ≤ 60 kV) and collisions (mostly on transmission lines > 60 kV). In North America, the most influential documents in APP development are the Avian Power Line Interaction Committee's (APLIC) Best Practices Manuals (BPMs); current versions: APLIC (2006) for electrocution mitigation and APLIC (2012) for collision mitigation. At the time of this writing, APLIC (2006), the single most important document for mitigating raptor electrocutions in North America, is now 14 yr old and urgently needs to be updated.

The collection of research in this special issue offers an opportunity to reflect on progress in mitigating electrocutions and collisions involving

raptors and electric systems, and to consider where to go from here. In conservation, many victories are temporary and many losses permanent. Raptors' interactions with electric power infrastructure may be one of the few places where, through modifications in management of risks associated with overhead electrical systems, renewable energy, and their associated infrastructure, it may be possible to create something closer to permanent victories and avoid the permanent losses.

ACKNOWLEDGMENTS

We thank EDM International, Inc. (Fort Collins, CO), Power Line Sentry (Fort Collins, CO), Kaddas Enterprises, Inc. (Salt Lake City, UT), and TE Connectivity's Raychem Wildlife and Asset Protection product group (Fuquay-Varina, NC) for helping us bring these pages to print.

LITERATURE CITED

- Avian Power Line Interaction Committee (APLIC) (2006). Suggested Practices for Avian Protection on Power Lines: The State of the Art in 2006. Edison Electric Institute, APLIC, and the California Energy Commission, Washington, DC, and Sacramento, CA, USA.
- Avian Power Line Interaction Committee (APLIC) (2012). Reducing Avian Collisions with Power Lines: The State of the Art in 2012. Edison Electric Institute and APLIC, Washington, DC, USA.
- Bedrosian, G., J. D. Carlisle, B. Woodbridge, J. R. Dunk, Z. P. Wallace, J. F. Dwyer, R. E. Harness, E. K. Mojica, G. Williams, and T. Jones (2020). A spatially explicit model to predict the relative risk of Golden Eagle electrocutions. *Journal of Raptor Research* 54:110–125.
- Demeter, I., M. Horváth, K. Nagy, Z. Görögh, P. Tóth, J. Bagyura, S. Solt, A. Kovács, J. F. Dwyer, and R. E. Harness (2018). Documenting and reducing avian electrocutions in Hungary: A conservation contribution



- from citizen scientists. *Wilson Journal of Ornithology* 130:600–614.
- Dixon, A., N. Batbayar, B. Bold, B. Davaasuren, T. Erdenechimeg, B. Galtbalt, P. Tzolmonjav, S. Ichinkhorloo, A. Gunga, G. Purev-Ochir, and L. M. Rahman (2020). Variation in electrocution rate and demographic composition of Saker Falcons electrocuted at power lines in Mongolia. *Journal of Raptor Research* 54:136–146.
- Dixon, A., M. D. L. Rahman, B. Galtbalt, B. Bold, B. Davaasuren, N. Batbayar, and B. Sugarsaikhan (2019). Mitigation techniques to reduce avian electrocution rates. *Wildlife Society Bulletin* 43:476–483.
- Dwyer, J. F., B. D. Gerber, P. Petersen, W. E. Armstrong, and R. E. Harness (2020a). Power pole density and avian electrocution risk in the western United States. *Journal of Raptor Research* 54:93–109.
- Dwyer, J. F., B. D. Gerber, P. Petersen, and R. E. Harness (2017). Power Pole Density and Avian Electrocution Risk in the Great Basin, the Columbia Plateau, and Montana. Final Report submitted to the US Fish and Wildlife Service. Western Golden Eagle Team, Lakewood, CO, USA.
- Dwyer, J. F., R. E. Harness, B. D. Gerber, M. A. Landon, P. Petersen, D. D. Austin, B. Woodbridge, G. E. Williams, and D. Eccleston (2016). Power pole density informs spatial prioritization for mitigating avian electrocution. *Journal of Wildlife Management* 80:634–642.
- Dwyer, J. F., R. K. Murphy, D. W. Stahlecker, A. M. Dwyer, and C. W. Boal (2020b). Golden Eagle perch site use in the U.S. Southern Plains: Understanding electrocution risk. *Journal of Raptor Research* 54:126–135.
- Dwyer, J. F., R. C. Taylor, and G. A. French (2020c). Failure of utility pole perch deterrents modified during installation. *Journal of Raptor Research* 54:172–176.
- Guil, F., M. Ángeles Soria, A. Margalida, and J. M. Pérez-García (2018). Wildfires as collateral effects of wildlife electrocution: An economic approach to the situation in Spain in recent years. *Science of the Total Environment* 625:460–469.
- Heck, N., and S. Schwartze (2020). Use of falconry and shooting as Rock Pigeon abatement techniques at an electrical converter station in Alberta, Canada. *Journal of Raptor Research* 54:193–197.
- Hernández-Lambrano, R. E., J. A. Sánchez-Agudo, and R. Carbonell (2018). Where to start? Development of a spatial tool to prioritise retrofitting of power line poles that are dangerous to raptors. *Journal of Applied Ecology* 55:2685–2697.
- Kemper, C. M., T. I. Wellicome, D. G. Andre, B. J. McWilliams, and C. J. Nordell (2020). The use of mobile nesting platforms to reduce electrocution risk to Ferruginous Hawks. *Journal of Raptor Research* 54:177–185.
- Mojica, E. K., C. E. Rocca, J. Luzenski, R. E. Harness, J. L. Cummings, J. Schievert, D. D. Austin, and M. A. Landon (2020). Collision avoidance by wintering Bald Eagles crossing a transmission line. *Journal of Raptor Research* 54:147–153.
- Mojica, E. K., B. D. Watts, J. T. Paul, S. T. Voss, and J. Pottier (2009). Factors contributing to Bald Eagle electrocutions and line collisions on Aberdeen Proving Ground, Maryland. *Journal of Raptor Research* 43:57–61.
- Moreira, F., R. C. Martins, I. Catry, and M. D'Amico (2018). Drivers of power line use by White Storks: A case study of birds nesting on anthropogenic structures. *Journal of Applied Ecology* 55:2263–2273.
- Rosenberg, K. V., A. M. Dokter, P. J. Blancher, J. R. Sauer, A. C. Smith, P. A. Smith, J. C. Stanton, A. Panjabi, L. Helft, M. Parr, and P. P. Marra (2019). Decline of the North American avifauna. *Science*. DOI: 10.1126/science.aaw1313.
- Sarasola, J. H., M. A. Galmes, and B. D. Watts (2020). Electrocution with power lines is an important threat for the endangered Chaco Eagle (*Buteogallus coronatus*) in Argentina. *Journal of Raptor Research* 54:166–171.
- Shaw, J. M., T. A. Reid, M. Schutgens, A. R. Jenkins, and P. G. Ryan (2018). High power line collision mortality of threatened bustards at a regional scale in the Karoo, South Africa. *Ibis* 160:431–446.
- Slater, S. J., M. Murgatroyd, and J. F. Dwyer (2020). Conservation letter: Raptors and overhead electrical systems. *Journal of Raptor Research* 54:198–203.
- Smith, J. A., and J. F. Dwyer (2016). Avian interactions with renewable energy infrastructure: An update. *The Condor: Ornithological Applications* 118:411–423.
- Smith, J. P., C. M. Lenihan, and J. A. Zirpoli (2020). Golden Eagle breeding response to utility-scale solar development and prolonged drought in California. *Journal of Raptor Research* 54:154–165.
- Tincher, M. C., J. F. Dwyer, G. E. Kratz, A. Watrud, and R. E. Harness (2020). Perch management may reduce raptor electrocution risk on horizontal post insulators. *Journal of Raptor Research* 54:186–192.